



CONCRETE SCHEDULE			
VOLUME (CUBIC YARDS)			
APPROACHES			9.0
FLOOR			34.7
TOTAL			43.7
MISC. STEEL			
PIT COPING	3 X 3 X 1/4	23 LN .FT	113 LBS

REVISION				
REV	ECO	DESCRIPTION	INIT	DATE




CONCRETE LAYOUT



DETAIL C




DETAIL D



DESIGNED BY: JONAS S. JOHNSON 02/17/2017		DRAWN BY: JONAS S. JOHNSON 02/17/2017		FIELD APPROVAL: JONAS S. JOHNSON 08/17/2017		RICE LAKE WEIGHING SYSTEMS	
TREATMENT NONE		THIS DRAWING AND INFORMATION CONTAINED HEREIN IS AND REMAINS THE PROPERTY OF RICE LAKE WEIGHING SYSTEMS INC. - HEREINAFTER REFERRED TO AS RLWS. IT MAY BE USED ONLY FOR RLWS' PROPOSAL AND/OR ITS CUSTOMER'S ORDERS. IT SHALL NOT BE DISCLOSED OR COPIED WITHOUT RLWS SPECIFIC WRITTEN CONSENT AND SHALL BE IMMEDIATELY RETURNED UPON REQUEST.		UNLESS OTHERWISE SPECIFIED UNITS TO BE INCHES ALL THREADS TO BE CLASS 2 ALL DIMENSIONS APPLICABLE AFTER TREATMENT		DESCRIPTION FOUNDATION, CONCRETE SLAB 80' X 11' OTR SERIES TRUCK SCALE	
NUMBER OF CRANES: MINIMUM CRANE CAPACITY: ESTIMATED WEIGHT (POUNDS):		DO NOT SCALE DRAWING SURFACE FINISH TOLERANCES UNLESS OTHERWISE SPECIFIED .XX: ± .XXX: ± ANGLE: ±		SCALE: 1:45 SHEET: 2 OF 3 MATERIAL:		THIRD ANGLE PROJECTION: PTH 180188	
						REV: A1	


MATERIAL REQUIREMENTS				
REBAR SCHEDULE				
BAL. NO.	QUANTITY	LENGTH (FT.-IN.)	DESCRIPTION	WEIGHT
A	24	9' 6"	# 4 @ 12 O.C.	152
B	22	10' 10"	# 4 @ 12 O.C.	159
C	24	1' 9 3/4"	# 4 @ 12 O.C.	29
D	30	81' 6"	# 4 AS SHOWN	1633
E	125	10' 10"	# 4 AS SHOWN	905
TOTAL WEIGHT OF REBAR (LBS.)				2878
TOTAL LENGTH OF REBAR (FT.)				4309

REBAR LAYOUT




APPROACH STANDARD VIEW


NOTES: 1) LEFT AND RIGHT APPROACHES ARE MIRROR IMAGES OF EACH OTHER AND CONTAIN AN IDENTICAL PART LIST








REBAR SPACING LENGTH



REBAR SPACING WIDTH



ISSUED BY DATE S. JOHNSON 02/17/2017		DRAWN BY DATE S. JOHNSON 02/17/2017		REVISION DATE S. JOHNSON 08/17/2017			
TREATMENT NONE		THIS DRAWING AND INFORMATION CONTAINED HEREIN IS THE PROPERTY OF RICE LAKE WEIGHING SYSTEMS INC. HEREINAFTER REFERRED TO AS RLV. IT MAY BE USED ONLY FOR RLVING PROPOSALS, AND ITS CUSTOMER. OTHERWISE, IT SHALL NOT BE DISCLOSED OR COPIED WITHOUT RLV'S SPECIFIC WRITTEN CONSENT AND SHALL BE IMMEDIATELY RETURNED UPON REQUEST.		UNLESS OTHERWISE SPECIFIED UNITS TO BE INCHES. ALL THREADS TO BE CLASS 2 ALL DIMENSIONS APPLICABLE AFTER TREATMENT			
NUMBER OF CRANES: 		TOLERANCES DO NOT SCALE DRAWING UNLESS OTHERWISE SPECIFIED .XX: ± .XXX: ± ✓ ANGLE: ±		DESCRIPTION FOUNDATION, CONCRETE SLAB 80' x 11' OTR SERIES TRUCK SCALE			
MINIMUM CRANE CAPACITY: 		SCALE 1:192		SHEET 3 OF 3		MATERIAL	
ESTIMATED WEIGHT (POUNDS) 				REV		180188 A1	